

AS2293.3 APPENDIX B

DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

Manufacturer: Evolt Pty Ltd
Address: U5/105a Vanessa Street,
 Kingsgrove, NSW 2208, Australia



Last updated: 21 May 2021_V1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN			
ORDER CODE	PRODUCT NUMBER	SKU	QTY
EV-RAZOR-SWING-24M-PRO-B Swing Slimblade Emergency Exit, Black	9336462145463	14546	4
EV-RAZOR-SWING-24M-PRO-B-LK Lynk Razor Swing Slimblade Emergency Exit, Black - w/wireless	9336462145487	14548	4
<input type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied		
<input checked="" type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained		
<input checked="" type="checkbox"/> Maintained	<input type="checkbox"/> Non-maintained		
<input checked="" type="checkbox"/> Combined			

OPERATIONAL INFORMATION	
GENERAL	
Mains Voltage	240V~ 50Hz
Ambient temp.	0 to 40°C
Class	1
Diffuser type	Polycarbonate
BATTERY	
Number of cells	2
Type	LiFePO ₄
Nominal Voltage	6.4 V
Capacity	1500mAh
Part number	1302

WALTEK (CNAS L9951)	
TEST	DESCRIPTION
Safety Standards	IEC 60598-1:2014+A1:2017 AS/NZS 60598.1:2017+A1:2017 IEC 60598-2-22:2014+A1:2017 AS 60598.2.22:2019 / IEC 60598-2-1:1979+A1:1987 AS/NZS 60598.2.1:2014+A1:2016+A2:2019 EN 61058-1:2016 / IEC 61058-1:2001+A2:2007 AS/NZS 61058.1:2002+A2:2008 IEC 62031:2018 / IEC/TR 62778:2014 AS/NZS 2293.3:2018
Safety / Performance Test Report	WTS19D11077927L
EMC standards	AS/NZS CISPR 15: 2011
EMC Test Report	WTS19S11077953E

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

Title: Managing Director **Date:** 20/05/21

Signature:

LIGHTLAB	
AS2293 TESTING	DESCRIPTION
Thermal Report	200419TH
Pictogram Report	200421LU
Classification	N/A

ektor.com.au
E: sales@evolt.com.au
 P:1300 4EVOLT (438 658)

NOTE: This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.