evolt PEARL PROFESSIONAL IP65 - SER II COMPLIANCE

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer:	Evolt Pty Ltd
Address:	U5/105a Vanessa Street
	Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION			
BRAND	MODEL	SKU	
Ektor	EV-PEARL-PRO-IP65-EM-S	11964	

COMPLIANCE	
2293 Report	WTF22F03034546N
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3
	AS/NZS 4268 IEC 62386-102 IEC 62386-103

OPERATIONAL INFORMATION		
IP Rating	IP65	
Working Temp Range	0 to 40 °C	
Input voltage	230Vac	
Input Frequency	50 Hz	
Electrical Rating	Class I	
Driver Type	DALI DT1 and DT8 Dimmable	
Product Type	EM LIGHT NETWORK	

EMERGENCY INFORMATION	
Emergency Mode	Maintained
Emergency Duration	90 mins
Emergency Classification	C0:D40, C90:D40
Replacement Battery Code	01302

DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director

Date: 05/01/2022

Signature:

Neukl

SDoC Document ID: PEARL-PROFESSIONAL-IP65---SER-IL_11964_AU | Generated on 27th of April 2024 12:58:21 - Page 1