

## AS2293.3 APPENDIX B

### DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

**Manufacturer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street,  
 Kingsgrove, NSW 2208, Australia



Last updated: 6 November 2020\_V1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN			
ORDER CODE	PRODUCT NUMBER	SKU	QTY
<b>EV-LED FIRE-PRO</b> Ledfire Professional Emergency Luminaire	9336462016947	01694	4
<b>EV-LED FIRE-PRO-LK</b> Lynk Ledfire Professional Emergency Luminaire - w/wireless	9336462102527	10252	4
<b>EV-LED FIRE-PRO-B-LK</b> Lynk Ledfire Professional Emergency Luminaire, Black - w/wireless	9336462102534	10253	4
<input checked="" type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied		
<input type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained		
<input type="checkbox"/> Maintained	<input checked="" type="checkbox"/> Non-maintained		
<input type="checkbox"/> Combined			

OPERATIONAL INFORMATION	
GENERAL	
Mains Voltage	240V~ 50Hz
Ambient temp.	0 to 40°C
Class	2
Diffuser type	Polycarbonate
BATTERY	
Number of cells	2
Type	LiFePO <sub>4</sub>
Nominal Voltage	6.4 V
Capacity	3000mAh
Part number	1303

TUV SUD (SHENZHEN)	
TEST	DESCRIPTION
Safety Standards	IEC 60598-1:2014 / IEC 60598-2-2:2011 IEC 60598-2-22:2014 EN 60598-1:2015 / EN 60598-2-2:2012 EN 60598-2-22:2014 / EN 62493:2015 AS/NZS 60598.1:2017 AS/NZS 60598.2.22:2005 AS/NZS60598.2.2:2016+Amdt1:2017 AS 2293.3:2005+Amdt1:2010+Amdt2:2012
Safety Certification	SG PSB-LE-01353(CB) N8A 180796151030(LVD)
Safety / Performance Test Report	211-1417672-000(CB) 681401767201(LVD)
EMC standards	EN 55015:2013/A1:2015 EN 61000-3-3:2013 AS/NZS CISPR 15:2017 EN 6100-3-2:2014 EN 61547:2009
EMC Certification	E8A 096151 0037(EMC)
EMC Test Report	687401728801(EMC)

LIGHTLAB	
AS2293 TESTING	DESCRIPTION
Thermal Report	LL1525302T
Photometric Report	LL18938
Classification	D63

### DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

**Title:** Managing Director **Date:** 27/10/20

**Signature:**

**NOTE:** This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.

ektor.com.au  
**E: sales@evolt.com.au**  
**P: 1300 4EVOLT (438 658)**

**evolt**  
 the electrical evolution

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.