

## AS2293.3 APPENDIX B

### DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

**Manufacturer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street,  
 Kingsgrove, NSW 2208, Australia



Last updated: 27 October 2020\_V1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN			
ORDER CODE	PRODUCT NUMBER	SKU	QTY
<b>EV-TWINSPOOT-WP-LITE</b> Twinspot IP65 Lite Emergency Luminaire	9336462110546	11054	4
<input checked="" type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied		
<input type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained		
<input type="checkbox"/> Maintained	<input checked="" type="checkbox"/> Non-maintained		
<input type="checkbox"/> Combined			

TUV SUD (SHENZHEN)	
TEST	DESCRIPTION
<b>Safety Standards</b>	IEC 60598-1:2014 / IEC 60598-2-2:2014 IEC 60598-2-1:1979 IEC 60598-2-1:1979/AMD1:1987 EN 60598-2-22:2014 / EN 60598-2-1:1989 EN 60598-1:2015 / EN 62493:2015 AS/NZS 60598.2.22:2005 AS/NZS 60598.2.1:2014+A1:2016 AS/NZS 60598.1:2017 AS/NZS 2293.3:2005+Amdt1:2010+Amdt2:2012
<b>Safety Certification</b>	SG PSB-LE-00989(CB) N8A 180196151017(LVD)
<b>Safety / Performance Test Report</b>	211-1417008-000(CB) 681401700801(LVD)
<b>EMC standards</b>	EN 55015:2013/A1:2015      EN 6100-3-2:2014 EN 61000-3-3:2013      EN 61547:2009 AS/NZS CISPR 15: 2011
<b>EMC Certification</b>	E8A 180196151 023(EMC)
<b>EMC Test Report</b>	687401700701(EMC)

LIGHTLAB	
AS2293 TESTING	DESCRIPTION
<b>Thermal Report</b>	LL1724301T
<b>Photometric Report</b>	LL20491
<b>Classification</b>	N/A

OPERATIONAL INFORMATION	
GENERAL	
<b>Mains Voltage</b>	240V~ 50Hz
<b>Ambient temp.</b>	0 to 40°C
<b>Class</b>	2
<b>Diffuser type</b>	Polycarbonate
BATTERY	
<b>Number of cells</b>	2
<b>Type</b>	LiFePO <sub>4</sub>
<b>Nominal Voltage</b>	6.4 V
<b>Capacity</b>	1500mAH
<b>Part number</b>	1302

### DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

**Title:** Managing Director **Date:** 27/10/20

**Signature:**

**NOTE:** This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.

ektor.com.au  
**E: sales@evolt.com.au**  
 P:1300 4EVOLT (438 658)

**evolt**  
 the electrical evolution

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.