

AS2293.3 APPENDIX B

DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

Manufacturer: Evolt Pty Ltd
Address: U5/105a Vanessa Street,
 Kingsgrove, NSW 2208, Australia



Last updated: 17 May 2021_V1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN		
ORDER CODE	PRODUCT NUMBER	SKU
EV-BOXIT-SLIM-24M Boxit Slim Emergency Exit, 24M	9336462150535	15053
<input type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied	
<input checked="" type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained	
<input checked="" type="checkbox"/> Maintained	<input type="checkbox"/> Non-maintained	
<input checked="" type="checkbox"/> Combined		

OPERATIONAL INFORMATION	
GENERAL	
Mains Voltage	240V~ 50Hz
Ambient temp.	5 to 40°C
Class	2
Diffuser type	Polycarbonate
BATTERY	
Number of cells	1
Type	LiFePO ₄
Nominal Voltage	3.2 V
Capacity	1500mAh
Part number	13972

WALTEK (CNAS L9950)	
TEST	DESCRIPTION
Safety Standards	EN 60598-1:2015+A1:2018 EN 60598-2-22:2014+A1:2017 EN 60598-2-1:1989 EN 62471:2008 / EN 62493:2015 AS/NZS 60598.2.22:2005 AS/NZS 60598.2.1:2014+A1:2016 AS/NZS 60598.1:2017+Amdt
Safety / Performance Test Report	WTS19F05029285L
EMC standards	EN 55015:2013/A1:2015 EN 6100-3-2:2014 EN 61000-3-3:2013 EN 61547:2009
EMC Certification	WTS19S05033946E

LIGHTLAB	
AS2293 TESTING	DESCRIPTION
Thermal Report	200954TH
Photometric Report	200955PH
Pictogram Report	200956LU
Classification	E1 E1

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

Title: Managing Director **Date:** 17/05/21

Signature:

ektor.com.au
E: sales@evolt.com.au
 P:1300 4EVOLT (438 658)

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.

NOTE: This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.